

Clean agent fire suppression annual maintenance checklist

The annual clean agent system service is the deep pass: the measurements, cleanings and tests a quarterly round doesn't reach. This checklist keeps the full service on record with the photos that make it defensible later. Work is commonly verified against NFPA 2001. Confirm the edition your authority having jurisdiction has adopted.

Who runs it: The licensed suppression contractor performs the annual service and room integrity (fan) test; facilities and IT walk it, observe and record. When: On the contractor's annual cycle, the pass that weighs or pressure-checks containers and re-proves the room will actually hold agent after a year of changes.

Service observed

- ☐ **Container weigh or pressure check witnessed**
Contractor's weighing or pressure verification watched, readings recorded against the tag, any container below limit noted for exchange. 2 photos required
- ☐ **Room integrity test result recorded**
Contractor's integrity (fan) test observed, the reported hold-time result written into the site record, remediation captured if it failed. 1 photo required

Sequence and record

- ☐ **Release, abort and interlock sequence walked through**
Contractor's functional check of detection to release, abort behavior and HVAC/damper interlock observed, outcomes recorded not certified by the site. 1 photo required
- ☐ **Service tag current and deficiencies logged**
Updated tag with the visit date on the panel or container bank, any integrity or supply issue the contractor raised logged with the follow-up. 1 photo required