

FRP wall panels final inspection checklist

FRP wall panels final inspection is where the punch list is either short or expensive. This checklist walks the finished work the way an owner or AHJ will see it: devices on, systems running, everything labeled. Each item gets the photo that closes it instead of reopening it. Work is commonly verified against the applicable building code, manufacturer's published instructions. Confirm the edition your authority having jurisdiction has adopted.

Who runs it: The panel installer with the GC's superintendent, walking the finished walls before the space is put into service.
When: After panels, trims and sealant are complete, before the kitchen or wet area is put into service and cleaned down.

Bond and flatness

- ☐ Panels fully bonded and flat
Full adhesive contact with no bubbles or lifting, panels flat and tight to the wall, seams aligned and even across the run. 2 photos required

Trims and joints sealed

- ☐ Division bars, trims and top edge sealed
Trims and division bars set with continuous sealant, top and bottom edges sealed, joints closed so wash water can not get behind the panels. 2 photos required

Penetrations

- ☐ Cutouts clean and sealed at outlets and pipes
Cutouts tight and centered, plates and escutcheons covering the edge, sealant closing the gap at every penetration. 1 photo required