

Rainscreen cladding punch checklist

Rainscreen cladding punch is where small misses become callbacks after the crew has demobilized. This checklist walks the finished work the way the owner and the next trade will see it, with the photo that closes each item instead of a note that reopens it. Work is commonly verified against the applicable building/energy code, manufacturer's published instructions. Confirm the edition your authority having jurisdiction has adopted.

Who runs it: The cladding crew on a callback, or the GC's superintendent clearing exterior punch items before turnover. When: During closeout, after staging comes down and after other trades and weather have marked the finished skin.

Panel repair

- ☐ Scratched or dented panels repaired or replaced
Damaged panels located and photographed, finish repaired or panel swapped to match, wide shot placing the repair on the elevation. 2 photos required

Vents and cavity re-checked

- ☐ Weeps and vents cleared and drainage re-confirmed
Blocked weeps and vents cleared, joints confirmed open, cavity drainage re-checked so nothing traps water behind the finished panels. 1 photo required