

Resinous flooring punch checklist

Resinous flooring punch is where small misses become callbacks after the crew has demobilized. This checklist walks the finished work the way the owner and the next trade will see it, with the photo that closes each item instead of a note that reopens it. Work is commonly verified against manufacturer's published instructions. Confirm the edition your authority having jurisdiction has adopted.

Who runs it: The flooring applicator on a callback, or the GC's superintendent closing floor punch items. When: During closeout, after traffic and cleaning reveal weak bond and pinholes the initial walk missed.

Repair

- ☐ Each defect located and photographed in context
A close shot of the delamination, pinhole cluster or damaged area plus a wide shot locating it in the room. 2 photos required
- ☐ Areas cut back, patched and topcoated to blend
Failed film cut back to sound material, patch built to the surrounding thickness and topcoated so the repair blends in color and texture. 2 photos required

Signoff

- ☐ No remaining flooring items before the area is released
All punch items in each room closed with photos and the repairs cured before the floor is turned over. 1 photo required