

Segmental pavers and hardscape punch checklist

Segmental pavers and hardscape punch is where small misses become callbacks after the crew has demobilized. This checklist walks the finished work the way the owner and the next trade will see it, with the photo that closes each item instead of a note that reopens it. Work is commonly verified against ICPI guidance, the project specifications. Confirm the edition your authority having jurisdiction has adopted.

Who runs it: The GC's superintendent closing hardscape punch items with the foreman on a callback. When: During closeout and after the surface has taken some traffic and weather, which is when settlement and joint loss first show.

Surface repairs

- ☐ **Settled or rocking pavers reset**
Loose or sunken pavers lifted, the bedding or base corrected beneath them, and the pavers reset flush and stable. **2 photos required**
- ☐ **Joints refilled and weeds cleared**
Open or washed-out joints cleaned, weeds removed, and joint sand replaced and compacted. **1 photo required**

Edges

- ☐ **Edge movement corrected before signoff**
Any spreading or shifted edge course re-restrained and brought back to line before the area is released. **2 photos required**