

Spray-applied fireproofing punch checklist

Spray-applied fireproofing punch is where small misses become callbacks after the crew has demobilized. This checklist walks the finished work the way the owner and the next trade will see it, with the photo that closes each item instead of a note that reopens it. Work is commonly verified against AWCI guidance, the applicable building code, manufacturer's published instructions. Confirm the edition your authority having jurisdiction has adopted.

Who runs it: The fireproofing foreman on a patch call, or the GC's superintendent closing out concealed-space punch above the ceiling line. When: During closeout after MEP rough-in and ceiling work, once the trades that drill, hang and cut into coated steel have finished.

Damage and omissions

- ☐ **Each bare or damaged spot located and photographed**
A close shot of the exposed steel plus a wide shot placing it on the grid line, above-ceiling areas checked by lifting tiles. **2 photos required**
- ☐ **Penetrations and hanger points inspected**
Steel around new drilled anchors, sleeves and pipe supports checked for coating knocked loose during installation. **2 photos required**

Patch and proof

- ☐ **Patches applied to the same build and re-photographed**
Repaired areas troweled or sprayed to the required thickness with the specified material, each patch photographed before the ceiling closes. **2 photos required**