

Spray polyurethane foam insulation punch checklist

Spray polyurethane foam insulation punch is where small misses become callbacks after the crew has demobilized. This checklist walks the finished work the way the owner and the next trade will see it, with the photo that closes each item instead of a note that reopens it. Work is commonly verified against the applicable building code, manufacturer's published instructions. Confirm the edition your authority having jurisdiction has adopted.

Who runs it: The applicator on a callback, or the GC's superintendent clearing insulation punch before the cavity closes. When: During closeout, after the final walk flagged thin bays or overspray and before board or cladding covers the foam for good.

Repair

- ☐ **Thin or missed areas re-sprayed and re-probed**
Marked bays given a second lift and the depth re-probed to confirm it now meets the specified thickness. 2 photos required
- ☐ **Pull-away gaps filled**
Shrinkage gaps at framing filled and re-checked for adhesion, no gap left at the stud or plate. 1 photo required

Cleanup

- ☐ **Overspray removed without damaging finishes**
Overspray cleaned off windows, panels and finished surfaces, the surface underneath undamaged, masking removed. 1 photo required