

Wall and corner protection final inspection checklist

Wall and corner protection final inspection is where the punch list is either short or expensive. This checklist walks the finished work the way an owner or AHJ will see it: devices on, systems running, everything labeled. Each item gets the photo that closes it instead of reopening it. Work is commonly verified against manufacturer's published instructions, the applicable building code. Confirm the edition your authority having jurisdiction has adopted.

Who runs it: The GC's superintendent with the wall protection installer, walking finished corridors and rooms before turnover.
When: After the protection is fully installed on finished walls, before the owner's punch walk and before corridors open to use.

Alignment and continuity

- ☐ **Rails, guards and panels level and plumb**
Handrails and crash rails level along the run, corner guards plumb, panels flat with even reveals, no waves or dips. **2 photos required**
- ☐ **Continuous at corners, splices and transitions**
Runs continuous through inside and outside corners and at splices, end caps and transitions tight, corner arris fully covered. **2 photos required**

Anchorage

- ☐ **Anchorage secure and pull-checked**
Fasteners landed in the backing, brackets tight, a hand pull on rails and guards confirms no give or loose sections. **2 photos required**

Heights and clearance

- ☐ **Mounting heights and accessible clearances observed**
Rail and guard heights measured against the specified mounting heights, handrail wall clearance and clear width at corridors verified. **2 photos required**