READY TO INSPECT — FIELD CHECKLIST

Wall and corner protection punch checklist

Wall and corner protection punch is where small misses become callbacks after the crew has demobilized. This checklist walks the finished work the way the owner and the next trade will see it, with the photo that closes each item instead of a note that reopens it. Work is commonly verified against manufacturer's published instructions, the applicable building code. Confirm the edition your authority having jurisdiction has adopted.

Who runs it: The wall protection installer on a callback, or the GC's superintendent closing Division 10 punch items before turnover. When: During closeout, after corridors have seen cart and equipment traffic that reveals loose runs and knocked splices.

Condition walk

- [ ] Guard and rail covers checked for cracks and popped sections
  Each corner guard and rail cover looked at along its length for cracks, dents, gouges or popped snap-on sections from cart traffic; damaged covers marked for replacement.
  1 photo required
- [ ] Edge gaps at the wall checked along every run
  Joint between guard, rail or panel edge and the wall face checked; open gaps re-seated or closed with the manufacturer's sealant so carts can't catch the edge.
  1 photo required
- [ ] Door and frame protectors checked for lifting edges
  Where door protection is installed, edges and corners at the hinge and latch side checked for lifting or peeling; loose ones re-bonded or replaced.
  No photo required

Defect repair

- [ ] Each loose or misaligned section located
  A close shot of the condition plus a wide shot locating the run in the corridor or room, cause noted before rework.
  2 photos required
- [ ] End caps, splices and color touch-up completed
  End caps refitted, splices realigned, color and finish touch-up matched, section re-checked tight afterward.
  No photo required
- [ ] Reset sections back at their mounting height and line
  Any section taken down and re-fastened during punch measured back to its mounting height and in line with the adjacent run.
  No photo required
- [ ] Re-fastening holes on fire-rated walls treated as drawn
  Where a section on a fire-rated wall was moved or re-fastened, old holes and new fasteners treated with the listed method the drawings show.
  No photo required

Signoff

- [ ] No remaining protection items before the area is released
  All punch items per corridor or room closed with photos, runs pull-checked once more before turnover.
  1 photo required
- [ ] Replacement covers match the neighboring run
  Where covers or guards were swapped from attic stock, color and texture match the adjacent run under the corridor lighting, noted before the area is released.
  No photo required